



**AHMEDABAD MUNICIPAL CORPORATION**  
**FIRE AND EMERGENCY SERVICES DEPARTMENT**

DANAPITH FIRE STATION (HEADQUARTERS), NR.AMC OFFICE, DANAPITH, AHMEDABAD

NOC Number: NOC823610082022

Category: School

NOC Issue Date: 23/08/2022

**NO OBJECTION CERTIFICATE**

This is to certify that management of M/s ZYDUS SCHOOL FOR EXCELLENCE , GODHAVI located at SURVEY NO.766&767 , GODHAVI VILLAGE , OPP.VANSHREE FARM , BOPAL - SANAND ROAD , AHMEDABAD. has installed necessary Fire Protection Equipments mentioned below.

**Hydrant System With**

- \* Main Pump - ( 1 Nos.)
- \* Fire Bridge Inlet (2/4 Way) - ( 1 Nos.)
- \* Hose Reel - ( 11 Nos.)
- \* Manual Call Point - ( 10 Nos.)
- \* Fire Alarm System Installed Yes

**Fire Extinguishers**

- \* 6 Kg. Capacity ABC Type - ( 33 Nos.)
- \* 4.5 Kg. Capacity Co2 Type - ( 24 Nos.)
- \* 9 Liter Capacity Water/Co2 Type - ( 1 Nos.)
- \* Different Sizes And Capacity Of Fire Extinguishers - ( 2 Nos.)
- \* Modular Type - ( 4 Nos.)

All the Fire Protection Equipments installed shall be maintained in working order throughout the validity period of this certificate.

**This Certificate is valid for TWO YEAR from the date of issue.**



*Ahudia*

(JAYESH N. KHADIA)  
Chief Fire Officer (I/c)

Ahmedabad Municipal Corporation